

EXHIBIT A – USER CLASSIFICATION TABLE
 CLASSIFICATION OF USERS AND BASIS FOR DETERMINATION OF WASTEWATER
 VOLUME DISCHARGE DEMAND

<u>User Classification</u>	<u>Wastewater Volume Discharge Demand Factor</u>
Single Family Residence (Occupied or vacant)	1.0
Accessory dwelling to a single family residential Apartment and Mobile Home Parks Each Unit	1.0 1.0
Motels and Hotels	0.25/Room
Rooming House	0.25/Room
Campgrounds	
Overnight & trailer w/central dump facilities	0.2/Space
RV w/individual hookup	0.5/Space
Barber Shops	1.0
Beauty Shops	2.0
Service Station	
With Public Restrooms	2.6
Self Service (no restroom)	1.0
Recreational Vehicle Dump Station	1.0/Dump Station
Automobile Repair Shops	1.0
Mortuary	1.0
Bakeries, Catering Service	1.0
Restaurants	
Walk-in	0.08/Seat
24 hour	0.19/Seat
w/banquet facilities	0.05/Seat
Drive-in, Short Order, kitchen only	1.0
Bars, Taverns	0.09/Seat
Bowling Alley	0.46/Alley
Theaters, indoor (Based on maximum seat capacity)	0.02/Seat
Laundries & Laundromats	0.5/Machine
Cleaners	0.7/Machine
Plant w/office	0.07/employee+ 1.62/Machine
Fire Station	1.0
Professional Offices	1.0
Physician or Dental Office or Clinic	1.0/office or M.D.

CLASSIFICATION OF USERS AND BASIS FOR DETERMINATION OF WASTEWATER VOLUME
DISCHARGE DEMAND

<u>User Classification</u>	<u>Wastewater Volume Discharge Demand Factor</u>
Retail Stores, Including:	2.0
Clothing	
Building Supply, Hardware, Appliance	
Furniture	
Real Estate	
Warehouse	
Drug Store	
Pet Shops	
Other Retail/Thrift Stores	
Public Swimming Pools	1.0
Car Wash, Self-Serve	2.8/Stall
Food Markets	2.0+
With Garbage Grinders	1.0/Grinder
Fairgrounds	4.0
Public Buildings and Facilities	1.0
Hospital	0.8/Bed
Schools	0.07 Per ADA
Meeting Halls and Churches	1.0
Public Restroom Buildings	1.16/Toilet 0.47/Wash Basin
Long-term Care Facilities	0.42/Bed
Industrial Bldg., Assembly, etc.	0.7/Employee or Per Discharge Permit
Minimum Demand Flow For Non-Commercial Classifications	1.0
Minimum Demand Flow for Commercial Classifications	2.0