



The District opted to take over responsibility of the above combined private lateral system for the following reasons:

- 1) Combined system was installed more according to mainline specs.
- 2) Ease of access at both ends of combined system.
- 3) Pipe inspection revealed pipe is in good condition,
- 4) Best way to provide service up to property line(s).
- 5) Privately owned cleanouts are appropriately placed, showing responsibility boundaries between District and customers.

009-121-013

TUOLUMNE CITY SANITARY DISTRICT
PLOT PLAN



18532 ROZIER AVENUE



SCALE: 1"=40'

BLACKWATER
CONSULTING ENGINEERS, INC.

602 LYELL DRIVE, MODESTO, CA 95356 PH. 209.322.1820